

**Cristina Haworth**

---

**From:** Doug Schlepp  
**Sent:** Thursday, December 17, 2020 1:00 PM  
**To:** Chris Grabowski; Cristina Haworth  
**Cc:** Lucy Sloman  
**Subject:** Re: ISD HS4 GS17 Noise

Thanks Chris!

Christina,

I have reviewed the report with respect the State/City standards. While they provided a model, we will want to do field noise level testing following the construction of the elements described in the report. I will condition the report regarding this matter.



**Doug Schlepp, Development Services 425.837.3432**

---

**From:** Chris Grabowski <chrisgr@issaquahwa.gov>  
**Sent:** Thursday, December 17, 2020 10:50 AM  
**To:** Doug Schlepp <DougS@issaquahwa.gov>  
**Cc:** Lucy Sloman <LucyS@issaquahwa.gov>  
**Subject:** RE: ISD HS4 GS17 Noise

Doug –

Upon review of their report I don't see anything too glaring. My main concerns would be the scene shop noise if the loading bay doors are open in warmer weather, and any mechanical units that exceed nighttime levels in the course of normal operations. As a reminder, those would have to exceed levels at the property line of the affected property. Other things, like vehicle noise, backup warning beeps, and unamplified human voices, are typically exempt from regulation under the WAC. **This is just my assessment of this report, and does not imply approval of any equipment or use that may violate City of State noise regulations.**

**CHRIS GRABOWSKI**

Code Enforcement Officer |City of Issaquah  
 Office: (425) 837-3107



This email and any responses to it may be subject to public disclosure.

---

**From:** Doug Schlepp <DougS@issaquahwa.gov>  
**Sent:** Monday, December 7, 2020 2:26 PM  
**To:** Chris Grabowski <chrisgr@issaquahwa.gov>  
**Subject:** ISD HS4 GS17 Noise

Here is the document we discussed.

SDP20-00001\_1R\_Noise-Study\_2020-10-06

